



ITEMS IN RED NOT SUPPLIED BY HENDRIX

ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	ANGLE BRACKET, HENDRIX TYPE BA3-35	1	25kV 61° -90° ANGLES
2	DOUBLE INSULATED PLATE, HENDRIX TYPE 2IP	3	
3	INSULATOR TYPE, HENDRIX HPI-25VTP	6	TITLE
4	INSULATOR PIN, HENDRIX TYPE SSP-2	6	CONSTRUCTION USING BA3-35 AND 2IP PLATES
5	EYEBOLT, 3/4" X REQ. LENGTH	2	DRAWING NO. REV
6	MESSENGER (SIZE AND TYPE AS REQUIRED)	AS REQ	AC1246-02 2
7	PRESHAPED MESSENGER GRIP	2	DATE
8	GUY HOOK, CONTINENTAL NO. GA-56X, OR EQUAL	2	8/16/06
9	HENDRIX AERIAL CABLE (SIZE AND VOLTAGE AS REQUIRED)	AS REQ	
10	GROUND WIRE, SOFT DRAWN COPPER, SOLID, #6 AWG	AS REQ	
11	GROUND WIRE STAPLE	AS REQ	
12	CONNECTOR (SIZE AND TYPE AS REQUIRED)	1	
13	MACHINE BOLT 5/8" X REQ. LENGTH	2	
14	SQUARE WASHER, 2-1/4" X 2-1/4" X 3/16", MIN.	2	
15	THIMBLE CLEVIS, HENDRIX TYPE HDTC	2	



53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040