

ITEMS IN RED NOT SUPPLIED BY HENDRIX

_		_	
ITEM	DESCRIPTION	QTY	DESIGN PARAMETERS
1	MESSENGER BRACKET, HENDRIX TYPE BM-24	1	25kV-46kV
2	SPACER, HENDRIX TYPE RTL-46	1	LINE ANGLES: 0-6°
3	ANTI-SWAY BRACKET, HENDRIX TYPE BAS-24F	1	LINE ANGLES. 0-0
4	STIRRUP, HENDRIX TYPE TS-1	1	
5	HENDRIX AERIAL CABLE,(SIZE AND VOLTAGE RATING AS REQ.)	AS REQ	TITLE
6	MESSENGER, (SIZE AND TYPE AS REQUIRED)	AS REQ	3-PHASE RISER ON TANGENT LOCATION
7	HENDRIX LINEDUC	2	
8	FUSED CUTOUTS	3	
9	COVERED TAP WIRE, (SIZE AND TYPE AS REQUIRED)	AS REQ	DRAWING NO. REV
10	UNDERGROUND CABLE TERMINATOR DATE	3	AC1267-02,03 0
11	LIGHTNING ARRESTOR, (SIZE AND TYPE AS REQUIRED)	3	·
12	UNDERGROUND RISER CABLE, (SIZE AND TYPE AS REQUIRED)	AS REQ	8/18/10
13	CONDUIT	AS REQ	0/10/10
14	EQUIPMENT MOUNT	1	
15	GROUND WIRE, SOFT DRAWN, SOLID #6 AWG MIN.	AS REQ	MONARIV
16	CONNECTORS, (SIZE AND TYPE AS REQ.)	AS REQ	<i>H</i> endrix*
17	GROUND WIRE STAPLE	AS REQ	,
18	TAP CLAMP	3	AERIAL CABLE SYSTEMS
			53 OLD WILTON RD. • MILFORD, NH 03055 • 603-673-2040