



ITEM	HENDRIX PART NUMBER	DESCRIPTION	QTY
1	POLE-XX	POLE (TYPE, CLASS & LENGTH AS REQ.)	1
2	SC-ZA6.2	35-46KV, 1-PHASE PRIMARY - DOUBLE DEADEND ON DEADEND BRACKET	1
2.1	HDTC	THIMBLE CLEVIS - 40,000 LBS.	2
2.2	MG-0000	PREFORMED GRIP, MESSENGER (SIZE & KIND AS REQ.)	2
2.3	DEINS35	INSULATOR - DEAD END, 35KV	2
2.4	TC	CLEVIS - THIMBLE	2
2.5	CG-0000	PREFORMED GRIP, CONDUCTORS, COATED (SIZE & KIND AS REQ.)	2
2.6	BM-14	BRACKET - TANGENT MESSENGER, 14"	1
2.7	SSP-2	INSULATOR PIN, SHORT SHANK, 3/4" W/1" NYLON THREAD	1
2.8	HPI-35VTP-01	INSULATOR, 35KV VISE TOP, 1" PIN	1
2.9	DABL5/8	BOLT, DOUBLE ARMING, 5/8" X REQ. LENGTH	2
2.10	MBLT5/8-XX	BOLT, MACHINE, 5/8" X REQ. LENGTH	2
2.11	SWSH5/8	WASHER, SQUARE, 5/8 X 2-1/4"	6
2.12	LWSH5/8-XX	WASHER, SPRINGLOCK, 5/8"	6
2.13	SNUT5/8-XX	SQUARE NUT, 5/8"	2
2.14	ENUT5/8	NUT, EYE, 5/8"	4
3	SC-H.01G	GROUNDING GUIDE SPACER CABLE	1
3.1	GNDWIRE-XX	GROUNDWIRE, COPPER, #6 AWG (MIN) (LENGTH AS REQ.)	1
3.2	CONNECTOR-XX	CONNECTOR (SIZE & TYPE AS REQUIRED)	3
3.3	STAPLE-XX	GROUND WIRE STAPLE (SIZE & TYPE AS REQUIRED)	1
3.4	GNDASSY-XX	GROUND ASSEMBLY (TYPE AS REQ., NOT SHOWN)	1
4	SC-E.01G	GUYING GUIDE, SPACER CABLE	2
4.1	POLEEYE-XX	POLE-EYE PLATE (SIZE AND STRENGTH AS REQUIRED)	1
4.2	GUYSTRAIN-XX	GUY STRAIN (SIZE & TYPE AS REQUIRED)	1
4.3	GUYSTRAND-XX	GUY STRAND (SIZE AND TYPE AS REQUIRED)	1
4.4	ANCHORASSY-XX	ANCHOR AND ANCHOR ROD (SIZE AND TYPE AS REQUIRED)	1

RED ITEMS ARE NOT SUPPLIED BY HENDRIX

Hendrix[®]
AERIAL CABLE SYSTEMS

53 OLD WILTON RD. ■ MILFORD, NH 03055 ■ (603) 673-2040

DESIGN PARAMETERS:
KV CLASS: 35-46kV
LINE ANGLE: 0-6°

REVISION: 0

35-46KV, 1-PHASE PRIMARY
DOUBLE DEADEND

DRAWING NO.:
AC1194-03