



ITEM	HENDRIX PART NUMBER	DESCRIPTION	QTY
1	POLE-XX	POLE (TYPE, CLASS & LENGTH AS REQ.)	1
2	SC-ZC6.22	35-46KV, 3-PHASE PRIMARY DOUBLE SUPPORT - DOUBLE DEADEND, CROSSARMS	1
2.1	HDTG	THIMBLE CLEVIS - 40,000 LBS.	2
2.2	MG-0000	PREFORMED GRIP, MESSENGER (SIZE & KIND AS REQ.)	2
2.3	DEINS35	INSULATOR - DEAD END, 35KV	6
2.4	TC	CLEVIS - THIMBLE	6
2.5	CG-0000	PREFORMED GRIP, CONDUCTORS, COATED (SIZE & KIND AS REQ.)	6
2.6	LSP-1	INSULATOR PIN - LONG SHANK, 3/4" W/ 1" NYLON THREAD	6
2.7	HPI-35VTP-01	INSULATOR, 35KV VISE TOP, 1" PIN	6
2.8	XARM-8FT	CROSSARM, 3-5/8 X 4-5/8 X 8'-0"	2
2.9	BRACE-28IN	BRACE, 28"	4
2.10	DABLT5/8	BOLT, DOUBLE ARMING, 5/8" X REQ. LENGTH	4
2.11	EBLT3/4	BOLT, EYE, 3/4" X REQ. LENGTH	1
2.12	LSCREW1/2X4	SCREW, LAG, 1/2 X 4"	2
2.13	CBLT3/8	BOLT, CARRIAGE, 3/8 X 4-1/2"	4
2.14	SWSH5/8	WASHER, SQUARE, 5/8 X 2-1/4"	14
2.15	SWSH3/4	WASHER, SQUARE, 3/4 X 2-1/4"	2
2.16	LWSH5/8	WASHER, SPRINGLOCK, 5/8"	14
2.17	ENUT5/8	NUT, EYE, 5/8"	6
2.18	ENUT3/4	NUT, EYE, 3/4"	1
2.19	LNUT3/8	LOCKNUT, 3/8"	4
2.20	LNUT5/8	LOCKNUT, 5/8"	8
3	SC-H.01G	GROUNDING GUIDE SPACER CABLE	1
3.1	GNDWIRE-XX	GROUNDWIRE, COPPER, #6 AWG (MIN) (LENGTH AS REQ.)	1
3.2	CONNECTOR-XX	CONNECTOR (SIZE & TYPE AS REQUIRED)	3
3.3	STAPLE-XX	GROUND WIRE STAPE (SIZE & TYPE AS REQUIRED)	1
3.4	GNDASSY-XX	GROUND ASSEMBLY (TYPE AS REQ., NOT SHOWN)	1
4	SC-E.01G	GUYING GUIDE, SPACER CABLE	1
4.1	POLEEYE-XX	POLE-EYE PLATE (SIZE AND STRENGTH AS REQUIRED)	1
4.2	GUYSTRAIN-XX	GUY STRAIN (SIZE & TYPE AS REQUIRED)	1
4.3	GUYSTRAND-XX	GUY STRAND (SIZE AND TYPE AS REQUIRED)	1
4.4	ANCHORASSY-XX	ANCHOR AND ANCHOR ROD (SIZE AND TYPE AS REQUIRED)	1

RED ITEMS ARE NOT SUPPLIED BY HENDRIX



AERIAL CABLE SYSTEMS

53 OLD WILTON RD. ■ MILFORD, NH 03055 ■ (603) 673-2040

DESIGN PARAMETERS:

KV CLASS: 35KV

LINE ANGLE: 0-6°

REVISION: 4

35KV, 3-PHASE PRIMARY
DOUBLE DEADEND
CROSSARM (WOOD)

DRAWING NO.:
AC1265-03