



ITEM	HENDRIX PART NUMBER	DESCRIPTION	QTY
1	POLE-XX	POLE (TYPE, CLASS & LENGTH AS REQ.)	1
2	SC-TC6.3	69KV, 3-PHASE PRIMARY - DOUBLE DEADEND, VERTICAL	1
2.1	PSAC-01	CLAMP - PERMANENT STRINGING, ANGLE SUSPENSION W/ SHACKLE	1
2.2	GUYINSULATOR-10	STRAIN INSULATOR, GUY, CLEVIS-THIMBLE EYE, 36" LNG, 15,000 LB	6
2.3	DEINS69	INSULATOR - DEAD END, 69KV	6
2.4	TC	CLEVIS - THIMBLE	6
2.5	CG-0000	PREFORMED GRIP, CONDUCTORS, COATED (SIZE & KIND AS REQ.)	6
2.6	LP-INS-3	LINE POST INSULATOR, 69KV	3
2.7	TRUNNION-01	CLAMP - TRUNNION, FOR LINE POST INSULATORS	3
2.8	EBLT3/4-XX	BOLT, EYE, 3/4" X REQ. LENGTH	7
2.9	MLBT3/4-XX	BOLT, MACHINE, 3/4" X REQ. LENGTH	6
2.10	SWSH3/4-XX	WASHER, SQUARE, 3/4 X 2-1/4"	20
2.11	LWSH3/4-XX	WASHER, SPRINGLOCK, 3/4"	11
2.12	SNUT3/4-XX	SQUARE NUT, 3/4"	13
3	SC-E.01G	GUYING GUIDE, SPACER CABLE	1
3.1	POLEEYE-XX	POLE-EYE PLATE (SIZE AND STRENGTH AS REQUIRED)	1
3.2	GUYSTRAIN-XX	GUY STRAIN (SIZE & TYPE AS REQUIRED)	1
3.3	GUYSTRAND-XX	GUY STRAND (SIZE AND TYPE AS REQUIRED)	AS REQ
3.4	ANCHORASSY-XX	ANCHOR AND ANCHOR ROD (SIZE AND TYPE AS REQUIRED)	1
4	SC-H.01G	GROUNDING GUIDE SPACER CABLE	1
4.1	CONNECTOR-XX	CONNECTOR (SIZE & TYPE AS REQUIRED)	AS REQ
4.2	GNDWIRE-XX	GROUND WIRE, COPPER, #6 AWG (MIN) (LENGTH AS REQ.)	AS REQ
4.3	STAPLE-XX	GROUND WIRE STAPLE (SIZE & TYPE AS REQUIRED)	AS REQ
4.4	GNDASSY-XX	GROUND ASSEMBLY (TYPE AS REQ., NOT SHOWN)	1

RED ITEMS ARE NOT SUPPLIED BY HENDRIX



AERIAL CABLE SYSTEMS

53 OLD WILTON RD. ■ MILFORD, NH 03055 ■ (603) 673-2040

DESIGN PARAMETERS:

KV CLASS: 69KV

LINE ANGLE: 7-20°

REVISION: 4

69KV, 3-PHASE PRIMARY
DOUBLE DEADEND
VERTICAL CONFIGURATION

DRAWING NO.:
AC1268-05