



RED ITEMS ARE NOT SUPPLIED BY HENDRIX

ITEM	HENDRIX PART NUMBER	DESCRIPTION	QTY
1	POLE-XX	POLE (TYPE, CLASS & LENGTH AS REQ.)	1
2	SC-ZC2.1	35-46kV, 3-PHASE PRIMARY - MEDIUM ANGLE	1
2.1	PSAC-01	CLAMP - PERMANENT STRINGING, ANGLE SUSPENSION W/ SHACKLE	1
2.2	BA3-35	BRACKET - ANGLE, "C"	1
2.3	SSP-2	INSULATOR PIN, SHORT SHANK, 3/4" W/ 1" NYLON THREAD	3
2.4	HPI-35VTP-01	INSULATOR, 35kV VISE TOP, 1" PIN	3
2.5	EBLT3/4	BOLT, EYE, 3/4" X REQ. LENGTH	1
2.6	MBLT5/8	BOLT, MACHINE, 5/8" X REQ. LENGTH	2
2.7	SWSH3/4	WASHER, SQUARE, 3/4 X 2-1/4"	2
2.8	SWSH5/8	WASHER, SQUARE, 5/8 X 2-1/4"	2
2.9	LWSH5/8	WASHER, SPRINGLOCK, 5/8"	2
2.10	LWSH3/4	WASHER, SPRINGLOCK, 3/4"	1
2.11	LNUT3/4	LOCKNUT, 3/4"	1
2.12	LNUT5/8	LOCKNUT, 5/8"	2
3	SC-E.01G	GUYING GUIDE, SPACER CABLE	1
3.1	POLEEYE-XX	POLE-EYE PLATE (SIZE AND STRENGTH AS REQUIRED)	1
3.2	GUYSTRAIN-XX	GUY STRAIN (SIZE & TYPE AS REQUIRED)	1
3.3	GUYSTRAND-XX	GUY STRAND (SIZE AND TYPE AS REQUIRED)	AS REQ
3.4	ANCHORASSY-XX	ANCHOR AND ANCHOR ROD (SIZE AND TYPE AS REQUIRED)	1
4	SC-H.01G	GROUNDING GUIDE SPACER CABLE	1
4.1	GNDWIRE-XX	GROUND WIRE, COPPER, #6 AWG (MIN) (LENGTH AS REQ.)	AS REQ
4.2	CONNECTOR-XX	CONNECTOR (SIZE & TYPE AS REQUIRED)	AS REQ
4.3	STAPLE-XX	GROUND WIRE STAPE (SIZE & TYPE AS REQUIRED)	AS REQ
4.4	GNDASSY-XX	GROUND ASSEMBLY (TYPE AS REQ., NOT SHOWN)	1

Hendrix®

AERIAL CABLE SYSTEMS

53 OLD WILTON RD. ■ MILFORD, NH 03055 ■ (603) 673-2040

DESIGN PARAMETERS:

KV CLASS: 35kV

LINE ANGLE: 7-60°

REVISION: 1

35KV, 3-PHASE PRIMARY
MEDIUM ANGLE

DRAWING NO.:

AC1341-03