

ITEM	HENDRIX PART NUMBER	DESCRIPTION	QTY
1	POLE-XX	POLE (TYPE, CLASS & LENGTH AS REQ.)	1
2	POLEEYE-XX	POLE-EYE PLATE (SIZE AND STRENGTH AS REQUIRED)	3
3	HDTC	THIMBLE CLEVIS - 40,000 LBS.	1
4	MG-0000	PREFORMED GRIP, MESSENGER (SIZE & KIND AS REQ.)	4
5	MESSENGER	MESSENGER (SIZE & TYPE AS REQ.)	1
6	GUYSTRAIN-XX	GUY STRAIN (SIZE & TYPE AS REQUIRED)	5
7	SC	CLEVIS - SHACKLE	3
8	DEINS115	LAAP CS2-054-TC-125-B	3
9	TC	CLEVIS - THIMBLE	3
10	MBLT7/8-XX	BOLT, MACHINE, 7/8" X REQ. LENGTH	3
11	SNUT7/8-XX	SQUARE NUT, 7/8"	2
13	EBLT3/4-XX	BOLT, EYE, 3/4" X REQ. LENGTH	3
12	SNUT3/4-XX	SQUARE NUT, 3/4"	4
14	CABLE	HENDRIX AERIAL CABLE (SIZE & VOLTAGE RATING AS REQ.)	3



AERIAL CABLE SYSTEMS
53 OLD WILTON RD. MILFORD, NH 03055 (603) 673-2040

DESIGN PARAMETERS:

KV CLASS: 115kV LINE ANGLE:

115KV, 3-PHASE PRIMARY DEADEND VERTICAL CONFIGURATION DRAWING NO.:

REVISION: 0

AC-1508-06